

Certificate Number: 8775

# CERTIFICATE OF SUITABILITY

**THIS is to certify that articles of the same type as the article specified below and variations so specified are accepted by the OFFICE OF FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS3000 subject to the conditions stated.**

**Article:**

(Single phase, wall mounted power track system for heavy impact (5J) with tap-off unit contacts engaged within the system of stamped copper rails fixed in thermoplastic)

Trade Name: 'Mainline'

250V., a.c., 50Hz., 32A.

IP23

Identification: Type ML

Examined for compliance with: IEC 61534.1 : 2003

Issued to: Power & Data Corporation Pty Ltd

Nominated Marking: CS8775N

**Conditions:**

1. This certificate will be withdrawn automatically if an article of this type is declared pursuant to the Electricity (Consumer Safety) Act, 2004.
2. This certificate is issued subject to the article and accepted variations thereof being maintained at the standard of the article examined at the time of acceptance.

Approved: 28 February 2007

This approval expires 28 February 2012 unless suspended, cancelled, renewed or extended.



for Commissioner for Fair Trading